



A Study of IoT-Based Monitoring and Controlling Systems for Diesel Electrical Generators

Ahmed Z. Khalaf^a, Asmaa S. Hammoodi^b

^aDepartment of the Electrical Engineering, College of Engineering, University of Tikrit, Iraq
Email: ahmed.zidan.khalaf@st.tu.edu.iq; ORCID: <https://orcid.org/0009-0000-1623-5072>

^bDepartment of the Electrical Engineering, College of Engineering, University of Tikrit, Iraq
Email: asmaa.s.hammoodi@tu.edu.iq; ORCID: <https://orcid.org/0000-0003-0440-964X>

PAPER INFO

Paper history

Received: 16/08/2024

Revised: 19/11/2024

Accepted: 10/12/2024

Keywords:

IoT-enabled system,
Remote monitoring,
Remote controlling,
Electrical generators,
Sensors.



Copyright: ©2023 by the authors. Submitted for possible open access publication under the terms and conditions of the Creative Commons Attribution (CC BY-4.0) license.

<https://creativecommons.org/licenses/by/4.0/>

ABSTRACT

Diesel electrical generators are essential for providing reliable backup power during grid outages, ensuring the continuous operation of critical services such as hospitals, industries, and communication systems. These generators require instantaneous monitoring and control to optimize their performance and longevity. The Internet of Things facilitates efficient monitoring and enables remote control with a faster response time than human intervention, thereby helping to prevent potential damage or system failures. This research introduced the Internet of Things technology and its general architecture. The study first presented an abstract framework of IoT-based monitoring and controlling technology, divided into three layers: perception, network, and application. It then discussed the terminology related to electrical generators, the parameters monitored, and their operational environments. In addition, the advantages and challenges associated with integrating it with electrical generators were discussed. Finally, the research reviewed and analyzed several practical applications and case studies integrating IoT with diesel electrical generators, highlighting key challenges and proposing solutions. This work provided theoretical and practical insights into IoT-based monitoring and control systems for electrical generators.

1 Introduction

Electrical generators play an essential role in meeting the energy demands of modern society, providing reliable power to industries, businesses, and residential areas. They also function as critical backup systems, ensuring operational continuity independent of the primary power grid. Traditionally, these generators, often powered by diesel engines, necessitate manual inspection and data collection for monitoring critical operational indicators,

including but not limited to temperature, rotational speed, oil pressure, voltage, frequency, and current, etc. Manual monitoring is susceptible to errors, including delayed responses, which may result in significant operational issues and inefficiencies.

To address these limitations, integrating Internet of Things (IoT) technology with electrical generator systems offers alternative monitoring techniques that enhance reliability and efficiency. IoT enables real-time sensor data acquisition, facilitating continuous monitoring of key

performance parameters like voltage, current, temperature, and fuel consumption rate. This real-time monitoring allows for the early detection of potential failures and activating alarms for any undesirable parameter value [1]. In addition to monitoring, IoT technology enables remote access and control capabilities, allowing operators to adjust settings, troubleshoot issues, and manage shutdowns or startups remotely. Analysis of collected sensor data further supports predictive maintenance strategies, optimizing maintenance schedules, reducing downtime, and extending the operational lifespan of generators [2]. Moreover, the capacity for remote monitoring and control of multiple generators from a centralized platform enhances overall system efficiency and resource allocation, streamlining operations and mitigating carbon dioxide emissions.

Despite the numerous benefits of IoT-based generator management solutions, several technical and operational challenges must be addressed. These include data security concerns, such as the risk of unauthorized access and data violation, and compatibility issues between diverse IoT devices and platforms.

1.1 Research Objectives

The objectives of this research are, firstly, introducing the IoT architecture and the used technologies in monitoring and controlling diesel electrical generators and examining the integration of IoT components, such as sensors, communication protocols, and user-end applications, that enable effective monitoring and control. Secondly, it highlights the benefits of IoT-based monitoring, including real-time data acquisition, predictive maintenance, and remote-control capabilities. It identifies limitations like security concerns, technical complexities, integration with existing infrastructure, and user training requirements. Finally, real-world implementations and case studies will be examined to provide insights into practical applications across industrial, commercial, and remote settings.

2 IoT Architecture

IoT can be defined as a network of interconnected devices and objects that communicate and exchange data over the internet. These devices range from simple to advanced and complicated technologies, embedded with sensors, software, and other technologies that enable them to collect and distribute data. The architecture of an IoT system is critical in facilitating this communication and ensuring efficient data processing, scalability, and reliability.

IoT architecture can vary depending on several key factors. Scalability is a central aspect of

determining the system structure to ensure accommodating the planned number of devices as well as the ability to expand and increase data traffic without reducing the performance [3]. It also facilitates the seamless integration and communication across various platforms by supporting multiple devices and protocols. For some applications, the history of system performance is crucial. Thus, the system must ensure reliable storage solutions, maintain data integrity, and provide data retrieval and backup mechanisms. Quality of Service (QoS) is another fundamental aspect of IoT architecture, guaranteeing efficient data transmission with minimal latency and high availability. Lastly, security and privacy are paramount, as protecting data integrity and preventing unauthorized access is critical, especially since IoT devices often handle sensitive information.

According to these aspects and considerations, several architectural models have been proposed for IoT systems [4]. with the three-layer and five-layer architectures being the most commonly referenced frameworks.

The three-layer architecture includes the perception, network, and application layers. it is typically used in simple and small-scale IoT systems where a basic framework suffices. This model is preferable when rapid implementation and ease of management are priorities. In addition, it is a better selection for a system that requires real-time data processing, such as industrial automation; the architecture must minimize latency and provide reliable communication channels [5].

In contrast, the five-layer IoT architecture expands on the three-layer model by adding two additional layers: the processing layer, which handles data processing tasks, and the business Layer, which focuses on managing the overall IoT ecosystem. This model is preferable for large-scale, enterprise-level IoT systems that demand advanced functionalities.




Figure 1. IoT architecture models [5]

By incorporating the processing and business layers, this architecture facilitates sophisticated data storage, analysis, and processing capabilities and comprehensive management of business operations, user privacy, and application services. Therefore, when an IoT project necessitates detailed data handling, scalability, and integration with business strategies, the five-layer architecture offers a more robust and granular framework to meet these demands.

Figure 1 compares the three-layer and five-layer IoT architecture models.

3 IoT System of Electrical Generators

Due to its simplicity and efficiency, the three-layer architecture is ideal for IoT-based monitoring and control of diesel generators. It supports real-time monitoring with low latency and direct flow of data from sensors to users, enabling faster decision-making, which is crucial for optimizing generator performance [6]. Moreover, it is more cost-effective, requiring fewer resources for development and operation, making it suitable for smaller-scale systems. Furthermore, its ease of deployment and management makes it particularly advantageous for industrial or remote environments where diesel generators are commonly used. Overall, the three-layer architecture provides the best balance of simplicity, performance, and cost for monitoring and controlling diesel generators. These three layers of such a system are explained in detail in the coming subsections.

3.1 Perception Layer

The perception layer, the device layer, is the fundamental interface connecting the physical world with the IoT system. [7]. This layer comprises an array of sensors and actuators responsible for data acquisition and interaction with the environment. Since this layer interacts with different physical quantities, its architecture might vary significantly across applications. Such variations depend on several factors, including the types of physical quantities being measured, environmental conditions, operational speeds, and power sources. In the context of this research, which focuses on integrating IoT systems with diesel-powered electrical generators, the architecture of this layer will be specifically tailored to facilitate the monitoring and control of these generators. The devices within the perception layer can be classified into two groups, i.e., sensors and actuators.

3.1.1 Sensors

Sensors collect real-time data on various critical parameters. Diesel engines continuously monitor mechanical quantities such as engine temperatures to prevent overheating, track rotation speed (RPM) to ensure optimal performance and detect abnormal vibrations that might indicate mechanical faults or impending failures. Sensors preinstalled by engine manufacturers usually measure these physical parameters, and their real-time readings are displayed on the generator's dashboard or control panel for immediate awareness.

On the electrical side, sensors that measure voltage, current, frequency, and power factor are essential for assessing the generator's electrical output and ensuring that the production meets the required electrical standards [8]. The data gathered from mechanical and electrical sensors is transmitted through the network layer to the application layer, which can be analyzed for remote monitoring, predictive maintenance, and control purposes. Table 1 It shows the most common sensors used with IoT-based electrical generators for monitoring and controlling systems.

3.1.2 Actuators

Actuators are devices that convert energy, usually electrical, into action. They perform the control function by receiving signals from the IoT system and executing actions such as opening a valve. In the context of electrical generators, actuators are integral to the automation and real-time control processes [9].

These devices are essential for controlling various generator operational parameters. For instance, actuators can adjust the fuel supply to the engine and turn the engine on or off. Doing so helps maintain the desired output voltage and frequency, which are critical for the stable operation of electrical systems. Moreover, actuators contribute to the safety and reliability of electrical generators. They can be programmed to respond to specific conditions, such as overheating or overloading, by initiating protective measures like shutting down the generator or activating cooling mechanisms. This automated response capability minimizes the risk of damage and enhances the overall resilience of the power generation system [10].

3.2 Network Layer

The network layer is responsible for secure data transmission from the perception layer to higher layers, i.e., the application layer, and vice versa. By establishing channels capable of routing data

packets, managing network traffic, and performing data encryption [11]. The complexity of the network layer can vary so that it can be as simple as a physical link.

Table 1. The commonly used sensors with electrical generators [12- 14]

Sensor Type	Part Number	Output Type	Requirements
Speed/RPM Sensor	E6B2-CWZ6C	Digital pulses	needs an external pull-up resistor to function correctly.
Vibration Sensor	ADXL345 MEMS	Digital signal	it supports two types of interfacing, SPI or I ² C, to export its reading.
Fuel Level Sensor	Siemens VDO 221 545 00 09	Variable resistance	It requires a voltage divider circuit to convert resistance into voltage.
Voltage Sensor	Texas Instruments INA219	Digital output via I ² C interface	Integrated ADC and signal processing, no external conditioning needed.
Current Sensor	Allegro ACS712	Analog voltage proportional to current	require filtering to reduce noise.
Frequency Sensor	Schneider Electric RM35TF30	Relay outputs indicating frequency thresholds	Integrated control signals based on frequency monitoring.
Power Factor Sensor	Carlo Gavazzi WM1-96	Digital display and Modbus communication	Built-in processing
Temperature Sensor	LM35DZ	Analog voltage (10 mV/°C)	need amplification and filtering for precise temperature readings.

For example, Li et al. [15] used Ethernet cables for real-time monitoring and control. Conversely, it can be very complicated, such as using the already existing communication infrastructure, such as a cell phone coverage network or internet connection.

Furthermore, this layer supports advanced features such as priority handling and interrupt protocols [16], as well as data processing to enhance the capability for information operations, making it highly complex. However, most communicating devices over networks have limited power and processing capabilities. Thus, specific protocols have been developed or adapted to meet such requirements. **Error! Not a valid bookmark self-reference.** illustrates the main protocols used at the IoT network layer and provides a comprehensive overview of their descriptions, such as range distances, advantages, and disadvantages.

3.3 Application Layer

The application layer acts as a user interface for an IoT-enabled electrical generator, ranging from traditional controlling panels with gauges. It switches to advanced software applications that can be installed on a smartphone or a computer. This layer is mainly responsible for process, analyzing, and visualizing data, such as

monitoring parameters like frequency and voltage to detect performance issues. Furthermore, Advanced analytics, including machine learning algorithms, could also leverage the overall system performance, such as predicting the maintenance needs and optimizing operations. [17]. The application layer represents the brain of the system, so the system acts depending on the application and algorithms that are used. For example, to synchronize two electrical generators, synchronization algorithm needs to be enabled at the application layer. Once the conditions are met i.e. identical frequency, phases shift, and voltage, it gives instruction to join the output of the generators to share the load. L Liu et al. [18] discuss integrating IoT systems with electrical generators in smart cities, where smart applications assist operators in managing complex systems. Therefore, the application layer ensures power supply consistency, schedules maintenance, and enhances economic and environmental sustainability through smart, data-driven decisions [19].

4 Advantages of IoT

The integration of IoT technology into electrical generators comes with several advantages: Firstly, it enables remote access to the

generators, so it allows real-time monitoring from anywhere, which enhances the operational reliability and user convenience [20]. Secondly, it

allows the instantaneous response to potential issues and reduces the need for on-site technical support [21].

Table 2. Main protocols used in the IoT network layer [22- 24]

Protocol	Description
IPv6	It provides a 128-bit address space to accommodate many IoT devices, improve routing efficiency, and enhance security features. However, it is more complicated than Ipv4 and has potential compatibility issues.
6LoWPAN	It enables Ipv6 packets over low-power, low-bandwidth wireless networks with a typical range of 10 to 100 meters. It uses header compression and supports mesh networking. However, it includes limited data rates and potential security vulnerabilities.
RPL	A routing protocol for low-power and lossy networks is good regarding energy and latency. It supports various traffic patterns over variable ranges. However, it has implementation complexity and potential scalability issues.
ICMPv6	Integral to Ipv6, it handles error messages, address autoconfiguration, and node discovery; it is essential for network functions and support for stateless addressing. It has potential security vulnerabilities requiring robust protection
Zigbee IP	It incorporates Ipv6 into traditional Zigbee, allowing devices to communicate over IP networks with ranges of 10 to 100 meters, extendable via mesh networking. However, it has a large overhead, potential compatibility issues with traditional Zigbee devices, and configuration complexity.
6TiSCH	It combines 6LoWPAN with time-synchronized channel hopping of IEEE 802.15.4e for reliable industrial IoT networking over 10 to 100 meters with low latency and interference. Due to time synchronization and precise scheduling requirements, the setup is complex.
MPL	A multicast forwarding protocol for efficient data dissemination in low-power and lossy networks, dependent on the underlying physical network. It is efficient multicast communication and suitable for constrained devices. However, it has transmission delays, especially with large networks.

Furthermore, it enables applying smart algorithms at the application layer of IoT-based systems to predict maintenance, which significantly reduces downtime and related maintenance costs by anticipating failures before they occur [25]. Finally, generators can instantaneously improve the efficiency based on instant load, hence, better energy management and sustainability as well as less fuel consumption and carbon dioxide emissions [26]. These advantages cooperatively result in more resilient and cost-effective energy solutions.

5 Challenges of IoT

IoT-based monitoring and controlling electrical generator systems face some challenges; here are the most common ones. Firstly, upgrading the existing generator infrastructure to be IoT-enabled is a complicated process requiring significant technical expertise, representing a severe challenge to widespread IoT technology. [27]. Secondly, initializing IoT-based systems is relatively expensive, which might be another

obstacle stand before the deployment and integration of IoT with electrical generators [28]. Furthermore, the most concerning issue of IoT-based systems is data security and privacy. Since the data are transmitted over a network, it becomes susceptible to cyber-attacks that can disfunction the whole system. Resulting in technical and financial damage much greater than what IoT is supposed to avoid [29]. Finally, an IoT system usually utilizes various devices from different manufacturers, such as sensors, actuators, controllers, and communication protocols. That can result in potential incompatibilities, which, in turn, elevate the error rate and reduce the performance accuracy [30]. However, comprehensive user training programs and strategic planning are needed to ensure that IoT integration's proposed benefits are worth the expenses and complexities involved. In addition, robust cybersecurity measures are necessary to address these challenges and avoid failure in any aspect, financial, technical, or operational. [31].

6 Case Studies

Various real-world applications are examined as practical examples of IoT-enabled electrical generator systems to extend the understanding of IoT system architecture and operational principles. These systems illustrate substantial benefits in practice while highlighting specific challenges encountered during implementation and how they were solved.

6.1 Generators Monitoring and Predictive Maintenance

Yaseen M et al. demonstrated in [32] the design of an IoT-based system for real-time monitoring and predictive maintenance of diesel-engine-driven electrical generators. It incorporates various sensors, including vibration, temperature, and current sensors, to monitor essential parameters that indicate the generator's operational health. Data generated by sensors is processed locally using an Arduino and Raspberry Pi. The Arduino performs initial processing, which helps identify potential faults. While the Raspberry Pi acts as a connection gateway.

This system is innovative, but it has areas for improvement. The scope of monitored parameters is limited, focusing mainly on vibration, temperature, and current, while other indicators like fuel efficiency or exhaust emissions could provide a more comprehensive diagnosis. The reliance on edge devices like Arduino and Raspberry Pi may limit processing power, especially as data complexity grows. Fault simulation via toggle switches may not fully reflect real-world conditions, suggesting a need for testing with actual or historical fault data. Additionally, the system's reliance on network connectivity could delay real-time monitoring in remote areas, and security protocols for cloud data transmission should be strengthened to protect against cyber threats. Moreover, this system employs hardware-defined measurements. The reliance on physical sensors and direct measurements using dedicated hardware sensors could increase costs and limit compatibility. Addressing these points would enhance robustness and scalability.

6.2 Monitoring and Control Diesel Generator using the IoT Technology

Chandra, A. A., et al in [33] have introduced a cloud-based IoT monitoring and control system for diesel generators, organized into a three-layer architecture: data acquisition, cloud processing, and user interface/control. The data acquisition layer relies on hardware-based sensors connected to an Arduino microcontroller, which captures essential parameters such as voltage,

frequency, and fuel volume. This data is uploaded to the cloud using a GSM shield. While functional, this setup could be strengthened by adding more advanced data processing directly on the device, reducing the dependency on continuous cloud connectivity. Such a modification would enhance reliability, especially in remote areas with limited connectivity.

In the cloud processing layer, Thing Speak is the platform for storing and visualizing the generator data, with notifications triggered when anomaly readings are detected. Although Thing Speak offers basic visualization features, its customization and analytics capabilities are limited and slow for real-time applications. The system could be significantly improved by opting for a more robust cloud service incorporating machine learning for predictive maintenance and advanced analytics. This would allow the system to proactively anticipate maintenance needs and address issues rather than just responding to real-time data.

The user interface and control layer allow operators to monitor generator parameters and remotely control the device using a smartphone application. Alerts are sent through SMS and email, notifying the operator of any anomalies. While effective, this setup may need more real-time responsiveness in critical situations due to reliance on network quality. Integrating local fail-safe mechanisms for control would mitigate risks from potential network delays and improve system reliability. While the system effectively meets basic monitoring needs, enhancing on-device processing, upgrading cloud analytics, and improving control responsiveness would create a more resilient and robust solution.

6.3 Smart Emergency Generator Monitoring

Lim, H. S. et al as in [34] This is a research paper that proposes a smart IoT-based monitoring system for emergency generators. This system leverages IoT technology to monitor distributed emergency generators efficiently and reduce energy demands during peak hours by using these generators as additional power resources. It integrates various sensors (such as temperature, pressure, and fuel level). It transmits this data over a secure VPN to a control center using the Modbus protocol, which is then mapped to the IEC 61850 standard. This design provides real-time data on generator status, enhancing remote management capabilities. The system architecture comprises hardware and software elements that enable seamless sensor integration with the IEC 61850 protocol and an Ethernet modem for network connectivity. These components ensure data accuracy and transmission efficiency, allowing

remote monitoring over TCP/IP networks. The software relies on SCL Forge to model and map Modbus data to IEC 61850 format, effectively bridging traditional generator monitoring systems with advanced IoT technology.

Although this system significantly improves remote generator management, it shows some limitations. Using Modbus and IEC 61850 has advantages for compatibility, yet it restricts the system's flexibility in integrating with other IoT standards. Additionally, integrating cloud-based platforms with machine learning could provide real-time insights into generator performance, further reducing downtime and optimizing energy usage. Overall, while the system effectively meets core requirements, expanding its compatibility with modern cloud systems and predictive analytics would enhance its utility and robustness in emergency management applications

6.4 Automatic Generator Control System for Industry

Kulkarni, S. S. demonstrated in [35] an IoT-based automatic generator control system for industrial applications. Embedded systems and web interfaces enable real-time monitoring and remote control of industrial generators, which is essential for industries where maintaining consistent power is crucial. The system is designed to automate generator operations, such as starting and shutting down based on load demands, thus reducing the need for manual intervention and enhancing safety in high-risk environments.

The hardware for this system includes the ESP8266 Wi-Fi module, which facilitates network connectivity, and a Programmable Logic Controller (PLC) that serves as the core processing unit, interfacing with the sensors and MCU for seamless data transfer. These components allow the system to track various parameters instantaneously, including fuel levels, output power, and generator load, with alerts like SMS notifications when fuel levels are low. This design ensures administrators have a continuous overview of the generator's performance, accessible through a web-based dashboard. However, while ensuring compatibility with traditional setups, the system's reliance on PLC and MODBUS protocols may limit flexibility for broader IoT integration and the addition of predictive maintenance features.

The research also highlights the user interface, which displays generator metrics such as power output, fuel status, and temperature, creating an intuitive platform for administrators. While effective, the interface could be improved with more advanced data analytics, allowing for predictive insights and detailed usage patterns,

thus enhancing preventive maintenance capabilities. Overall, this IoT-based generator control system provides a cost-effective automation solution with substantial safety and operational benefits, though it could be further enhanced by integrating more versatile IoT protocols and analytics for proactive industrial maintenance.

7 Conclusion

This research presented an extensive detailed explanation of IoT architecture methodologies such as three and five layers. In addition, the working principle of the IoT system and its integration with the electrical generator were analyzed in-depth. Furthermore, multiple IoT-based generator monitoring and control case studies were examined, focusing on the types of equipment, connectivity methods, and control applications employed. The performance of these systems is evaluated to find out the actual results, where all these cases achieved acceptable results while facing some challenges like connectivity issues.

Future research should focus on developing hybrid systems with local data processing and cloud-based analytics that could enhance reliability by reducing dependency on constant connectivity. Implementing predictive maintenance and machine learning would support early fault detection and optimize maintenance schedules. Additionally, exploring alternative IoT protocols and strengthening cybersecurity would improve interoperability and safeguard critical systems. Finally, more intuitive interfaces and customizable dashboards would enhance operator control and provide actionable insights, creating a more robust IoT-driven solution for generator management.

References

- [1] M. Q. Taha, "Advantages and recent advances of smart energy grid," *Bulletin of Electrical Engineering and Informatics*, vol. 9, no. 5, pp. 1739-1746, 2020, doi:10.11591/eei.v9i5.2358
- [2] Kroposki, B., Pink, C., DeBlasio, R., Thomas, H., Simoes, M., & Sen, P. K., "Benefits of power electronic interfaces for distributed energy systems," *IEEE transactions on energy conversion*, vol. 25, no. 3, pp. 901-908, 2020, doi: 10.1109/TEC.2010.2053975
- [3] Sattar, K. A., & Al-Omary, A. "A survey: security issues in IoT environment and IoT architecture" In *3rd Smart Cities*

- Symposium SCS 2020, Vol. 2020, pp. 96-102) (2020, September), doi: 10.1049/icp.2021.0894
- [4] Washizaki, H., Ogata, S., Hazeyama, A., Okubo, T., Fernandez, E. B., & Yoshioka, "Landscape of architecture and design patterns for iot systems," *IEEE Internet of Things Journal*, vol. 7, no. 10, pp. 10091-10101, 2020, doi:10.1109/JIOT.2020.3003528
- [5] K. Mahmoud, "Comprehensive Study of Attacks and Cryptographic Measures for Internet of Things Devices.," *The Journal of Scientific and Engineering Research*, vol. 8, pp. 174-188, 2021.
- [6] Mahdi, M. J., Aljuboori, A. F., & Hussein, A. M., "Smart stadium using cloud computing and Internet of Things (IoT): Existing and new models," *International Journal of Computer Applications Technology and Research*, vol. 10, no. 5, pp. 111-118, 2021.
- [7] Kaur, H., & Kumar, R., "A survey on Internet of Things (IoT): Layer-specific, domain-specific and industry-defined architectures," in *Proceedings of CICT 2019*, 2021.
- [8] V. V. S. I. M. a. D. A. S. Koltsov, "Voltage sensor for electrical switchgear and electrical switchgear comprising same". U.S. Patent Application Patent 17/770,210, 8 December 2022.
- [9] I. Boldea, "Electric generators and motors: An overview," *CES Transactions on Electrical Machines and Systems*, vol. 1, no. 1, pp. 3-14, 2017.
- [10] Saravanan, V., Ramachandran, M., & Selvam, M., "Interaction between technical and economic benefits in distributed generation," *Electrical and Automation Engineering*, vol. 1, no. 2, pp. 83-91., 2022.
- [11] Lombardi, M., Pascale, F., & Santaniello, D., "Internet of things: A general overview between architectures, protocols and applications.," *Information*, vol. 12, no. 2, p. 87, 2021.
- [12] Portalo, J. M., González, I., & Calderón, A. J., "Monitoring system for tracking a PV generator in an experimental smart microgrid: An open-source solution," *Sustainability*, vol. 13, no. 15, p. 8182, 2021.
- [13] Cui, J., Liu, H., Li, X., Jiang, S., Zhang, B., Song, Y., & Zhang, W., "Fabrication and characterization of nickel thin film as resistance temperature detector," *Vacuum*, vol. 176, p. 109288, 2020.
- [14] I. Analog Devices, "ADXL345 Datasheet," 2010. [Online]. Available: <https://www.alldatasheet.com/datasheet-pdf/pdf/254714/AD/ADXL345.html>. [Accessed 20 5 2024].
- [15] Paniagua, C., & Delsing, J., "Industrial frameworks for internet of things: A survey.," *IEEE Systems Journal*, vol. 15, no. 1, pp. 1149-1159, 2020.
- [16] Kuo, Y. W., Li, C. L., Jhang, J. H., & Lin, S., "Design of a wireless sensor network-based IoT platform for wide area and heterogeneous applications," *IEEE Sensors Journal*, vol. 18, no. 12, pp. 5187-5197, 2018.
- [17] Fyodorova, V., Kornilovich, D., Kirichenko, V., Glazyrin, G., Sidorova, A., & Litvinova, A., "Synchronization digital device development for generators automatic connection to the network by various methods," in *Smart Energy Conference (USSEC)* (pp. 89-93), Siberian , 2021, November.
- [18] Liu, L., Guo, X., & Lee, C., "Promoting smart cities into the 5G era with multi-field Internet of Things (IoT) applications powered with advanced mechanical energy harvesters," *Nano Energy*, vol. 88, p. 106304, 2021.
- [19] Shafique, K., Khawaja, B. A., Sabir, F., Qazi, S., & Mustaqim, M., "Internet of things (IoT) for next-generation smart systems: A review of current challenges, future trends and prospects for emerging 5G-IoT scenarios," *Ieee Access*, vol. 8, pp. 23022-23040, 2020.
- [20] Mukhopadhyay, S. C., Tyagi, S. K. S., Suryadevara, N. K., Piuri, V., Scotti, F., & Zeadally, S., "Artificial intelligence-based sensors for next generation IoT applications: A review," *IEEE Sensors Journal*, vol. 21, no. 22, pp. 24920-24932, 2021.
- [21] Khan, W. Z., Rehman, M. H., Zangoti, H. M., Afzal, M. K., Armi, N., & Salah, K., "Industrial

- internet of things: Recent advances, enabling technologies and open challenges," *Computers & electrical engineering*, vol. 81, p. 106522, 2020.
- [22] Mansour, D. E. A., Numair, M., Zalhaf, A. S., Ramadan, R., Darwish, M. M., Huang, Q., Abdel-Rahim, O., " Applications of IoT and digital twin in electrical power systems: A comprehensive survey.," *IET Generation, Transmission & Distribution*, vol. 17, no. 20, pp. 4457-4479, 2023.
- [23] Hossein Motlagh, N., Mohammadrezaei, M., Hunt, J., & Zakeri, B., "Internet of Things (IoT) and the energy sector," *Energies*, vol. 13, no. 2, p. 494, 2020.
- [24] "LM135 data sheet," Texas Instruments, [Online]. Available: <http://www.ti.com/product/LM135>. [Accessed 20 5 2024].
- [25] Nangia, S., Makkar, S., & Hassan, R., "IoT based predictive maintenance in manufacturing sector," in *Proceedings of the International Conference on Innovative Computing & Communications (ICICC)*, 2020, March.
- [26] Rathor, S. K., & Saxena, D., "Energy management system for smart grid: An overview and key issues," *International Journal of Energy Research*, vol. 44, no. 6, pp. 4067-4109, 2020.
- [27] Nižetić, S., Šolić, P., Gonzalez-De, D. L. D. I., & Patrono, L., "Internet of Things (IoT): Opportunities, issues and challenges towards a smart and sustainable future," *Journal of cleaner production*, vol. 274, p. 122877, 2020.
- [28] Akintade, O., Yesufu, T., & Kehinde, L. J. I. J. T., "Development of an MQTT-based IoT architecture for energy-efficient and low-cost applications," *International Journal of Internet of Things*, vol. 8, no. 2, pp. 27-35, 2019.
- [29] Karie, N. M., Sahri, N. M., Yang, W., Valli, C., & Kebande, V. R., "A review of security standards and frameworks for IoT-based smart environments," *IEEE Access*, vol. 9, pp. 121975-121995, 2021.
- [30] Islam, M. M., Nooruddin, S., Karray, F., & Muhammad, G., "Internet of things: Device capabilities, architectures, protocols, and smart applications in healthcare domain," *IEEE Internet of Things Journal*, vol. 10, no. 4, pp. 3611-3641, 2022.
- [31] Salek, M. S., Khan, S. M., Rahman, M., Deng, H. W., Islam, M., Khan, Z., & Shue, M., "A review on cybersecurity of cloud computing for supporting connected vehicle applications," *IEEE Internet of Things Journal*, vol. 9, no. 11, pp. 8250-8268, 2022.
- [32] Yaseen, M., Swathi, D., & Kumar, T. A., "IoT based condition monitoring of generators and predictive maintenance," in *2nd international conference on communication and electronics systems (ICCES)*, 2017 October.
- [33] Chandra, A. A., Jannif, N. I., Prakash, S., & Padiachy, V., "Cloud based real-time monitoring and control of diesel generator using the IoT technology," in *20th International Conference on Electrical Machines and Systems (ICEMS)*, 2017, August.
- [34] Lim, H. S., Ryu, I. H., & Bang, J. H., "Smart Emergency Generator Monitoring System through IoT using IEC 61850. .," *Indian Journal of Science and Technology*, vol. 9, no. 44, pp. 1-6, 2016.
- [35] S. S. Kulkarni, "IoT-Based Automatic Generator Control System for Industry," *International Journal of Science and Research (IJSR)*, vol. 11, no. 8, pp. 923-926, 2022.